

**Addendum #1 IFB 21-30 REBID**



**CITY OF SOMERVILLE, MASSACHUSETTS**  
**Department of Purchasing**  
**JOSEPH A. CURTATONE**  
**MAYOR**

**To:** Bidders of Dilboy Turf and Track Renovation  
**From:** Andrea Caruth, Assistant Director of Purchasing  
**Date:** March 15, 2021  
**Re:** Responses to Request for Information

---

**Addendum No. 1 to IFB 21-30 REBID**

---

This addendum documents responses to all requests for information (RFIs) submitted by prospective applicants to this IFB.

The final and substantial completion dates were updated to the following:  
Substantial Completion Dates: June 25<sup>th</sup>, 2021  
Final Completion Date: July 23<sup>rd</sup>, 2021

The City must receive submittals 48 hours after the notice of award.

**\*Important note\*:** Due to the need for use of the field this summer, this project must meet all deadlines listed on page 3 and 17, and updated in this addendum. Liquidated damages will be strictly enforced after the **Date of Final Completion**. Please consider this carefully before submitting a bid.

**\*\*This addendum changes specifications. Failure to acknowledge this addendum will result in bid disqualification.\*\***

**NAME OF COMPANY / INDIVIDUAL:** \_\_\_\_\_

**ADDRESS:** \_\_\_\_\_

**CITY/STATE/ZIP:** \_\_\_\_\_

**TELEPHONE/FAX/EMAIL:** \_\_\_\_\_

**Addendum #1 IFB 21-30 REBID**

**SIGNATURE OF AUTHORIZED INDIVIDUAL:** \_\_\_\_\_

**ACKNOWLEDGEMENT OF ADDENDA:**

**Addendum #1** \_\_\_\_\_ **#2** \_\_\_\_\_ **#3** \_\_\_\_\_ **#4** \_\_\_\_\_

### Addendum #1 IFB 21-30 REBID

#	Question	Answer
1.	<p>We have a concern with the time frame of the project as it relates to asphalt repair, or new asphalt. A typical cure time for asphalt is upwards of 30 days without accelerants. In regards to any liquidated damages on this project, our track surfacing contractor may have concerns with spraying if the asphalt has not fully cured.</p> <p>Has the curing time been considered in regard to the project dates?</p>	<p>Refer to spec Section 321816-Resilient Sport Surfacing, Part-3.4.B.1 for surface preparation. We believe proper scheduling of work by the contractor will allow sufficient cure time of asphalt to complete resilient surfacing within the project schedule requirements.</p>