

MEMORANDUM

To: All Bidders
From: Andrew Leonard
Date: Monday, August 20, 2018
RE: Renovation of the Somerville Community Garden Center
Addendum #2

Please note the following revisions and clarifications to the bid documents for Renovation of the Somerville Community Garden Center, CPA Re- Bid #18-01.

1. Please allow for 745 linear feet of recycled plastic pathway edging as part of the base bid. Should the final amount required vary, the unit price schedule will apply and a change order issued.
2. There is no existing backflow preventer or cabinet on site.
3. The plumbing scope of work is as shown on the Utility Plan, sheet L-6. The scope consists of providing and installing a new valve and water spigot to replace the existing one along the path, and a new valve and spigot off the existing water line near the new annual beds.

The bid opening date is unchanged with this Addendum.

Thank you for your attention to these issues.