

Addendum #2 Quote 22-02



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
KATJANA BALLANTYNE
MAYOR

To: Prospective Quote Submitters of Preventative Maintenance of Dehumidification Unit
From: Andrea Caruth, Deputy Chief Procurement Officer
Date: February 22, 2022
Re: Response to Requests for Information

Addendum No. 2 to Quote 22-02

This addendum documents responses to all requests for information (RFIs) submitted by prospective applicants to this IFB.

If you submitted a quote and this addendum materially changes it, you can submit an updated quote.

****Please note: deadline for Quote Submissions extended to February 24th, 11:00AM to allow for the release of this addendum.****

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum #2 Quote 22-02

#	Question	Answer
1	Do you know if the intent is to repair/address all current issues before the new contract starts? If not, are we correct to assume that we would be expected to provide quotes for current repairs that are needed, using repair hours included in the contract and bill materials separately?	The City is unaware of any controller issues at this moment with the poolpak. The compressor has a leak and needs either replaced or rebuilt. This will be a separate item that we will need a quote for. Any extra work needed can be quoted separately aside from the contract.
2	Also, Scope of Work items #5 and 7 involve checking the compressor oil level and the refrigerant charge. Adding oil and/or refrigerant, if either is low, is not to be included in this maintenance contract, and would be quoted separately, correct?	Any refrigerant addition can be priced at a separate rate and will not be included in the contract as well.