

Addendum No. 1 to IFB 19-75



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB 19-75,
City Hall Boiler Renovation

From: Michael Richards, Assistant Purchasing Director

Date: April 24th, 2019

Re: Answer Questions; Append List of Pre-Bid Site Visit Attendees

Addendum No. 1 to RFQ 19-71

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

This addendum clarifies questions received at the optional pre-bid site visit and during the Q/A period. Please see that attached answers for all questions received.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB 19-75

Questions and Answers

- Q. Can you describe the finish of the ceilings and piping? Will the piping be concealed? Are they dropped ceiling?
- A. The new piping will be concealed and installed above the existing acoustical tile ceiling, refer to Drawings AD100 for extend of existing tile removal and AR100 for extent of new ACT ceiling. All new ceiling will be drop ceiling as well.
- Q. Is the enclosure building on a slab?
- A. Yes, the prefabricated enclosure building shall be supported on a cast-in-place concrete slab with edge beams and piers as shown on the Drawings: Detail D1/C-300 and A-300.
- Q. Is the enclosure pre-purchased and part of the GC package?
- A. Yes, the prefabricated enclosure building is specified under Section 13 34 19.
- Q. Is there a specific metal building already spec'd out?
- A. The basis of the design is a pre-fab and is included in the specifications and as shown in the Drawings.
- Q. Is the building of standard size?
- A. It will be designed to spec. and as shown on the Drawings.



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR


BID # IFB 19-75 DATE: 4/23/2019 TIME: 3:00pm

The following individuals were in attendance for a pre-bid meeting for:

City Hall Boiler Renovation

| Name | Company | Email Address | Phone Number |
|-----------------------------|-------------------------------------|---|------------------------------|
| Joe BOURGEOIS MARK CASSY | PJ Kennedy + Sons CASSY BROS INC | JBOURGOIS@PKENNY.COM MARKCASSY@VERIZON.NET | 617-440-8000 617 699 6675 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Under the penalties of perjury, the above list represents the names of all bidders in attendance at the pre-bid meeting and I declare that said list is a complete and accurate list of attendees.



Michael Richards
Assistant Purchasing Director

Witness