

Addendum No. 2 to IFB#18-33



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: All Parties on Record with the City of Somerville as Holding **IFB#18-33**
Removal of Underground Storage Tanks at DPW & West Somerville Neighborhood School

From: Thupten D. Chukhatsang

Date: 2/13/2018

Re: Question & Answers

Addendum No. 2 to IFB#18-33

As per Addendum#1, all bids are **due by 11:00 AM, Wednesday, February 21st, 2018** at the Purchasing Office, City Hall, 93 Highland Avenue, Somerville, MA 02143.

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 2 to IFB#18-33

Questions & Answers

- 1. The backfill spec does not say if we must supply certification that 95% compaction is met through compaction testing. Is certification required?**

Yes, it is required.

- 2. Do we need to consider unit cost for soil contamination – excavation, stockpiling and disposal?**

As of now, based on the history of the existing underground storage tanks installation and worked performed at that time, we don't anticipate any contamination soil related issue.

However, since the DPW site is under Activity and Use Limitations (AUL) status according to the Massachusetts Contingency Planning, we will have a soil management plan developed by the LSP.