

Addendum No. 1 to IFB-20-56



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB-20-56
Title Sidewalk Repairs

From: Prajкта Waditwar, Construction Procurement Manager

Date: 3/4/2020

Re: 1. Appends pre-bid conference attendance sheet
2. Answers some questions

Addendum No. 1 to IFB-20-56

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB-20-56

Question 1: For the ADA tiles, can you verify the size of the tile?

Answer: Size is determined by the size of the ramp. Most are 2'x4'. Color is brick red cast in place replaceable tactile.

Question 2: For the granite curb, can you mention the size of the curbing?

Answer: Curbing is typically resetting existing curb. Curb that needs to be added/replaced will be provided by the City.

Question 3: There is a drawing for channelize posts but they are not on the specification or bid price page. Can you please clarify?

Answer: "U" channel posts are galvanized post for the purpose of street signage. 3' stump into concrete with 12" exposed for mounting of sign post.

Question 4: There is a drawing for a bike rack, catch basin etc. but the specification does not specify the installation of bike racks / catch basin. Please clarify.

Answer: If an area being repaired has a bike rack/catch basin in place it is to be reinstalled in the same location.

Question 5: Form for General Bid mentions concrete sidewalk, concrete sidewalks at driveway and concrete wheelchair ramps is by the ton. Should this be by the cubic yard?

Answer: Yes- cubic yard

Question 6: SEC 4.0 Item numbers 10, 11, 12 are priced per ton concrete is sold in cubic yards not tons. Its common measurement for bidding is square yard. Asphalt is sold per ton.

Answer: Concrete-cubic yard
Asphalt –per ton



CITY OF SOMERVILLE, MASSACHUSETTS

Department of Purchasing

JOSEPH A. CURTATONE
MAYOR

Pre-bid meeting for: Sidewalk Repairs

BID # IFB#20-56

Date & Time: 03/04/2020 9:00AM EST

Company Name	Company Rep. Name	Email Address	Tel. #
THE Excavation LLC	Randi Zaneli	randi.zaneli@gmail.com	(978) 207-1233
			() -
			() -
			() -
			() -
			() -
			() -
			() -
			() -
			() -