



SOMERVILLE FIRE DEPARTMENT

Fire Prevention Bureau

D.P.W. Building

1 Franey Road

Somerville, Massachusetts 02143

617-623-1700 ext. 8400

NO DEMOLITION OR WELDING MAY START UNTIL DETAIL PERSON IS ON SITE.

FIRE DETAIL REQUIREMENTS

Detail Location: _____

Contractor: _____

Contact #: _____

Billing Address: _____

Start Date of Detail: _____ Time: _____

Estimated # Hours for Completion: _____ Estimated # Days for Completion: _____ Required Deposit: _____
(Days x \$1,113.20)

*******CONTRACTOR REQUIREMENTS*******

Deposit: The contractor shall submit the required deposit to the Somerville Fire Department Administration Office, 266 Broadway, Somerville, MA 02145 at least (7) days prior to the anticipated start of the detail. The deposit will be held until the completion of the detail at which point an exact cost invoice will be issued, the original check will be returned to the contractor and the contractor shall provide a check for the exact cost. If the detail exceeds the amount of deposit, the original check will be cashed and a new check will be required for the completion of the detail.

Scheduling: The contractor shall contact the District Chief at 617-623-1700 ext. 8357, 48 hours in advance of the starting date and time.

Cancellation: Cancellations must be requested twelve (12) hours in advance. **If cancellation is required less than twelve (12) in advance, the contractor will be required to pay a four (4) hour minimum.**

Fire Department Signature: _____ Contractor Signature: _____

Date: _____

Type of Detail and Equipment needed (Circle detail type)

Welding – Regular work uniform, portable radio, hardhat, vest and water extinguisher

Fire Watch – Regular work uniform, portable radio and handlight

Occupancy Detail – Class B Uniform with badge, portable radio, medical kit with defib

Medical Detail – Regular work uniform, portable radio, medical kit with defib

Demolition Detail – Regular work uniform, portable radio, bunker gear with helmet _____ 2 ½ "hose _____ 1 ¾" hose,
hydrant wrench, gated reducing wye, nozzle, spanner wrench and Water Meter

Other Detail / Memo - _____

“SPRINKLER SYSTEMS AND SMOKE DETECTORS SAVE LIVES”

www.somervillema.gov